

EXHIBIT "C1"
ARVIN-EDISON WATER STORAGE DISTRICT
WATER SUPPLY WATER QUALITY SUMMARY

	Date	Flow cfs	Import Source	Calcium		Magnesium		Sodium		Bicarbonate		Chloride		Nitrate		TDS	pH	EC umhos/cm	Hardness mg/l	SAR	Gypsum lbs/AF	Boron mg/l	Turbidity NTU
				mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l								
Intake Canal	03/04/26	210	FKC (100%)	18.0	0.9	9.2	0.8	31.0	1.3	66	1.1	35.0	1.0	3.3	0.05	210	7.6	310	83	1.3	0.1	120.00	19.5
	02/05/26	75	FKC (100%)	3.3	0.2	0.6	0.1	3.6	0.2	16	0.3	1.9	0.1	-	-	29	6.7	40	11	0.2	0.0	ND	4.5
	01/06/26	350	FKC (100%)	4.0	0.2	0.8	0.1	3.3	0.1	14	0.2	1.8	0.1	ND	ND	34	6.8	43	13	0.2	0.0	ND	39.0
	12/08/25	0	DOWN FOR MAINTENANCE/RESIDUAL	20.0	1.0	14.0	1.1	82.0	3.5	73	1.2	130.0	3.7	ND	ND	340	7.7	650	110	3.1	0.3	ND	4.7
	11/13/25	0	WELLS(100%)	14.0	0.7	4.0	0.3	22.0	0.9	58	1.0	17.0	0.5	ND	ND	130	7.9	200	51	1.0	0.1	100.00	9.1
	10/02/25	125	FKC (100%)	16.0	0.8	12.0	1.0	55.0	2.4	81	1.3	88.0	2.5	ND	ND	230	8.0	460	92	2.3	0.2	ND	2.6
	09/11/25	125	FKC (60%)/CVC (40%)	14.0	0.7	8.9	0.7	32.0	1.4	67	1.1	49.0	1.4	ND	ND	170	7.7	290	71	6.4	0.2	ND	3.4
	08/05/25	226	FKC (55%)/CVC (45%)	13.0	0.7	7.7	0.6	26.0	1.1	58	1.0	31.0	0.9	ND	ND	160	7.6	240	64	6.4	0.1	ND	4.6
	07/09/25	251	FKC (60%)/CVC (40%)	20.0	1.0	12.0	1.0	45.0	1.9	64	1.0	57.0	1.6	ND	ND	240	8.6	410	99	4.0	N/A	110.00	4.5
	06/17/25	201	FKC (50%)/CVC (50%)	17.0	0.9	9.9	0.8	33.0	1.4	70	1.1	41.0	1.2	ND	ND	190	8.1	340	84	5.0	0.1	110.00	5.1
	05/01/25	100	FKC (100%)	10.0	0.5	5.0	0.4	18.0	0.8	45.0	0.7	22.0	0.6	ND	ND	120.0	7.9	190.0	46.0	7.0	0.1	ND	6.6
	04/10/25	300	FKC (100%)	4.3	0.2	0.8	0.1	4.2	0.2	20.0	0.3	2.8	0.1	ND	ND	53.0	6.9	51.0	14.0	4.0	0.1	ND	28.2
	03/04/25	0	WELLS(100%)	19.0	1.0	9.6	0.8	34.0	1.5	58.0	1.0	38.0	1.1	ND	ND	290.0	9.2	340.0	88.0	4.4	0.1	110.0	13.0
02/11/25	70	CVC (100%)	21.0	1.1	12.0	1.0	46.0	2.0	75.0	1.2	55.0	1.5	1.4	0.02	220.0	8.5	420.0	100.0	3.6	0.2	170.0	6.0	
Average				13.8	0.7	7.6	0.6	31.1	1.3	54.6	0.9	40.7	1.1	2.4	0.0	172.6	7.8	284.6	66.1	3.5	0.1	120.0	10.8
North Canal	03/04/26	120	FKC (100%)	18.0	0.9	9.2	0.8	32.0	1.4	70.0	1.1	35.0	1.0	2.4	0.0	200.0	7.6	320.0	84.0	1.3	0.1	140.0	9.9
	02/05/26	48	FKC (100%)	3.9	0.2	0.6	0.1	3.7	0.2	19.0	0.3	2.1	0.1	-	-	33.0	6.7	46.0	12.0	0.2	0.0	ND	7.1
	01/06/26	82	FKC (100%)	5.3	0.3	0.7	0.1	2.8	0.1	22.0	0.4	1.6	0.0	ND	ND	35.0	7.9	47.0	16.0	0.2	0.0	ND	30.0
	12/08/25	0	DOWN FOR MAINTENANCE/RESIDUAL	31.0	1.6	6.0	0.5	68.0	2.9	130.0	2.1	37.0	1.0	12.0	0.2	330.0	8.1	520.0	100.0	3.0	0.4	660.0	5.1
	11/13/25	38	WELLS(100%)	20.0	1.0	3.8	0.3	50.0	2.2	100.0	1.6	22.0	0.6	11.0	0.2	240.0	8.3	340.0	66.0	2.5	0.3	360.0	2.3
	10/02/25	80	FKC (56%)/WELLS(44%)	23.0	1.2	6.6	0.5	59.0	2.5	97.0	1.6	42.0	1.2	11.0	0.2	220.0	7.6	420.0	85.0	2.6	0.2	400.0	3.6
	09/11/25	86	FKC (34%)/CVC (23%)/WELLS(44%)	21.0	1.1	5.7	0.5	45.0	1.9	92.0	1.5	30.0	0.8	6.5	0.1	240.0	8.4	340.0	75.0	8.1	0.3	320.0	3.5
	08/05/25	40	FKC (38%)/CVC (31%)/WELLS(31%)	24.0	1.2	6.1	0.5	47.0	2.0	95.0	1.6	28.0	0.8	6.5	0.1	230.0	7.2	360.0	85.0	4.6	0.3	330.0	3.3
	07/09/25	40	FKC (44%)/CVC (29%)/WELLS(27%)	24.0	1.2	7.9	0.6	52.0	2.2	87.0	1.4	39.0	1.1	6.9	0.1	240.0	8.4	410.0	92.0	4.1	N/A	340.0	5.1
	06/17/25	106	FKC (30%)/CVC (30%)/WELLS(40%)	33.0	1.7	9.8	0.8	48.0	2.1	100.0	1.6	37.0	1.0	11.0	0.2	290.0	8.3	470.0	120.0	0.7	0.2	330.0	4.9
	05/01/25	82	FKC (46%)/WELLS(54%)	29.0	1.5	8.4	0.7	52.0	2.2	97.0	1.6	41.0	1.2	7.8	0.1	270.0	8.4	460.0	110.0	1.9	0.3	390.0	6.3
	04/10/25	148	FKC (98%)/WELLS(2%)	6.4	0.3	1.0	0.1	5.8	0.3	26.0	0.4	3.4	0.1	ND	ND	32.0	7.2	71.0	20.0	4.4	0.1	ND	13.9
	03/04/25	28	WELLS(100%)	19.0	1.0	4.0	0.3	39.0	1.7	87.0	1.4	20.0	0.6	7.9	0.1	260.0	8.4	320.0	64.0	7.1	0.3	210.0	3.7
02/11/25	8	CVC (100%)	44.0	2.2	10.0	0.8	73.0	3.1	120.0	2.0	43.0	1.2	27.0	0.4	360.0	8.3	620.0	150.0	ND	0.3	560.0	10.8	
Average				21.5	1.1	5.7	0.5	41.2	1.8	81.6	1.3	27.2	0.8	10.0	0.2	212.9	7.9	338.9	77.1	3.1	0.2	367.3	7.8
South Canal	03/04/26	112	FKC (100%)	19.0	1.0	9.1	0.7	31.0	1.3	66.0	1.1	34.0	1.0	2.0	0.0	200.0	7.7	320.0	84.0	1.3	0.1	130.0	13.2
	02/05/26	30	FKC (100%)	4.2	0.2	0.7	0.1	3.7	0.2	20.0	0.3	2.1	0.1	-	-	34.0	6.7	46.0	13.0	0.2	0.1	ND	4.7
	01/06/26	10	FKC (100%)	6.2	0.3	0.8	0.1	3.0	0.1	27.0	0.4	1.5	0.0	ND	ND	41.0	7.1	53.0	19.0	0.2	0.0	ND	43.0
	12/08/25	0	DOWN FOR MAINTENANCE/RESIDUAL	19.0	1.0	3.5	0.3	39.0	1.7	95.0	1.6	18.0	0.5	4.4	0.1	180.0	7.8	310.0	63.0	2.0	0.3	270.0	9.8
	11/13/25	6	WELLS(100%)	18.0	0.9	3.6	0.3	51.0	2.2	84.0	1.4	23.0	0.6	13.0	0.2	230.0	8.8	340.0	59.0	2.5	0.3	340.0	7.3
	10/02/25	50	FKC (54%)/WELLS(46%)	27.0	1.4	7.5	0.6	50.0	2.2	93.0	1.5	36.0	1.0	6.7	0.1	220.0	8.0	390.0	97.0	2.1	0.3	290.0	2.2
	09/11/25	20	FKC (32%)/CVC (22%)/WELLS(46%)	23.0	1.2	6.6	0.5	42.0	1.8	98.0	1.6	30.0	0.8	5.9	0.1	230.0	7.6	340.0	85.0	4.4	0.3	250.0	2.4
	08/05/25	24	FKC (37%)/CVC (30%)/WELLS(33%)	26.0	1.3	8.3	0.7	45.0	1.9	100.0	1.6	36.0	1.0	5.8	0.1	250.0	8.3	400.0	99.0	2.9	0.2	210.0	2.9
	07/09/25	134	FKC (42%)/CVC (29%)/WELLS(29%)	25.0	1.3	8.0	0.7	45.0	1.9	100.0	1.6	33.0	0.9	5.9	0.1	220.0	8.3	380.0	96.0	3.2	N/A	250.0	3.3
	06/17/25	274	FKC (27.7%)/CVC (27.7%)/WELLS(44.6%)	29.0	1.5	7.3	0.6	51.0	2.2	110.0	1.8	33.0	0.9	7.4	0.1	270.0	8.1	440.0	100.0	1.8	0.3	380.0	3.1
	05/01/25	70	FKC (42%)/WELLS(58%)	26.0	1.3	7.2	0.6	49.0	2.1	96.0	1.6	33.0	0.9	13.0	0.2	240.0	8.2	420.0	95.0	3.4	0.3	400.0	2.8
	04/10/25	130	FKC (98%)/WELLS(2%)	7.0	0.4	1.1	0.1	5.9	0.3	27.0	0.4	3.4	0.1	ND	ND	32.0	7.0	75.0	22.0	4.3	0.1	ND	15.9
	03/04/25	16	WELLS(100%)	20.0	1.0	5.0	0.4	44.0	1.9	88.0	1.4	25.0	0.7	6.4	0.1	180.0	8.7	350.0	71.0	6.1	0.3	290.0	7.5
02/11/25	0	CVC (100%)	34.0	1.7	6.8	0.6	74.0	3.2	110.0	1.8	38.0	1.1	14.0	0.2	320.0	8.0	540.0	110.0	ND	0.4	630.0	6.1	
Average				20.2	1.0	5.4	0.4	38.1	1.6	79.6	1.3	24.7	0.7	7.7	0.1	189.1	7.9	314.6	72.4	2.6	0.2	312.7	8.9

EXHIBIT "C1"
ARVIN-EDISON WATER STORAGE DISTRICT
WATER SUPPLY WATER QUALITY SUMMARY

	Date	Flow cfs	Import Source	Calcium		Magnesium		Sodium		Bicarbonate		Chloride		Nitrate		TDS mg/l	pH	EC umhos/cm	Hardness mg/l	SAR	Gypsum lbs/AF	Boron mg/l	Turbidity NTU
				mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l								
Interte Pipeline	03/04/26	140	FKC (64%)/AQUEDUCT(34%)/SPILLWAY(6%)	18.0	0.9	9.3	0.8	32.0	1.4	67	1.1	36.0	1.0	3.1	0.1	210	7.6	320	83	1.3	0.1	130.00	16.4
	02/05/26	20	FKC (100%)	4.5	0.2	0.6	0.1	3.7	0.2	20	0.3	2.3	0.1	-	-	33	6.8	47	14	0.2	0.0	ND	5.5
	01/06/26	0	FKC (100%)	26.0	1.3	11.0	0.9	63.0	2.7	91	1.5	84.0	2.4	ND	ND	290	7.9	530	110	2.4	0.3	140.00	6.4
	12/08/25	0	DOWN FOR MAINTENANCE/RESIDUAL	21.0	1.1	12.0	1.0	66.0	2.8	75	1.2	92.0	2.6	ND	ND	290	7.9	550	100	2.6	0.3	120.00	5.7
	11/13/25	50	WELLS(50%)/AQUEDUCT(50%)	17.0	0.9	12.0	1.0	66.0	2.8	67	1.1	110.0	3.1	1.5	0.0	300	7.9	520	94	2.6	0.3	100.00	1.6
	10/02/25	35	FKC (47%)/WELLS(40%)/AQUEDUCT(13%)	18.0	0.9	9.1	0.7	47.0	2.0	67	1.1	58.0	1.6	ND	ND	210	9.1	390	83	1.9	0.2	160.00	16.0
	09/11/25	100	FKC (23%)/CVC (15%)/WELLS(32%)/AQUEDUCT(25%)/SPILLWAY(5%)	14.0	0.7	9.1	0.7	32.0	1.4	70	1.1	47.0	1.3	ND	ND	170	7.6	280	72	6.1	0.2	ND	4.0
	08/05/25	123	FKC (31%)/CVC (25%)/WELLS(28%)/AQUEDUCT(8%)/SPILLWAY (8%)	13.0	0.7	7.6	0.6	25.0	1.1	60	1.0	31.0	0.9	ND	ND	160	7.5	250	63	6.3	0.1	ND	5.5
	07/09/25	63	FKC (36%)/CVC (24%)/WELLS(25%)/AQUEDUCT(15%)	20.0	1.0	11.0	0.9	43.0	1.9	70	1.1	56.0	1.6	1.0	0.0	230	8.1	400	N/A	4.2	N/A	130.00	8.0
	06/17/25	40	FKC (27.7%)/CVC (27.7%)/WELLS(44.6%)	25.0	1.3	8.5	0.7	49.0	2.1	88	1.4	36.0	1.0	5.0	0.1	250	8.6	410	97	3.1	0.2	360.00	4.0
	05/01/25	40	FKC (36%)/WELLS(49%)/SPILLWAY(14%)	22.0	1.1	5.4	0.4	42.0	1.8	83.0	1.4	25.0	0.7	5.7	0.1	220.0	8.6	350.0	77.0	5.2	0.3	370.0	6.3
	04/10/25	0	FKC (98%)/WELLS(2%)	8.7	0.4	1.2	0.1	6.3	0.3	31.0	0.5	3.6	0.1	ND	ND	61.0	7.3	84.0	27.0	4.0	0.1	ND	12.4
	03/04/25	0	WELLS(100%)	24.0	1.2	7.3	0.6	41.0	1.8	87.0	1.4	29.0	0.8	5.1	0.1	280.0	8.6	370.0	90.0	3.9	0.2	210.0	13.2
	02/11/25	0	CVC (54%)/SPILLWAY (46%)	19.0	1.0	6.2	0.5	45.0	1.9	74.0	1.2	35.0	1.0	3.3	0.1	200.0	8.8	340.0	73.0	6.5	0.2	270.0	13.5
		Average			17.9	0.9	7.9	0.6	40.1	1.7	67.9	1.1	46.1	1.3	3.5	0.1	207.4	8.0	345.8	75.6	3.6	0.2	199.0

Water Supply Water Quality Note: ¹ Positive flow rate is reverse flow into the District. Where the reported value is ND, the method detection limit is entered.

Water Supply Water Quality Note: ² Reverse flow into the District South Canal (Sycamore check gate was closed).

Water Supply Water Quality Note: ³ Constituent ran past sample hold time.

ND: NONE DETECTED.
 N/A: NOT AVAILABLE OR NOT TESTED.
 PR: PENDING RESULTS

pH: A MEASURE OF ACIDITY. A pH < 7 IS ACIDIC, pH = 7 IS NEUTRAL, pH > 7 IS BASIC. NORMAL RANGE IS 6.5 - 8.4. A pH > 8 MAY NEED TO BE BUFFERED FOR PESTICIDE APPLICATION. AFFECTS NUTRIENT AVAILABILITY.

mg/l: MILLIGRAMS PER LITER; SAME AS PARTS PER MILLION (ppm).
 me/l: MILLEQUIVALENTS PER LITER; SAME AS EQUIVALENTS PER

EC: ELECTRICAL CONDUCTIVITY. A MEASURE OF WATER SALINITY; SOIL - IN MILLIMHOS PER CENTIMETER (mmho/cm); WATER - MORE OFTEN, IN MICROMHOS PER CENTIMETER (umhos/cm). EC < 700 (umhos/cm) HAS NO RESTRICTIONS FOR AGRICULTURAL USE. EC < 200 (umhos/cm) CAN REDUCE INFILTRATION RATE.

INTAKE: SAMPLE TAKEN AT COTTONWOOD RD. SOUTH OF PANAMA LANE.
 NORTH: SAMPLE TAKEN DOWNSTREAM OF SYCAMORE CHECK GATE.
 SOUTH: SAMPLE TAKEN DOWNSTREAM OF TEJON CHECK GATE.
 INTERTIE: TERMINUS OF SOUTH CANAL (S93 FOREBAY).

SODIUM: FOR SURFACE IRRIGATION: SAR < 3 IS GOOD. FOR SPRINKLER IRRIGATION: SODIUM < 3 me/l IS GOOD.

HARDNESS: HARD WATER, INDICATING CALCIUM AND MAGNESIUM, IS BENEFICIAL FOR AGRICULTURE.

NITRATE: NITRATE IN WATER SLIGHTLY REDUCES FERTILIZER REQUIREMENT.

BICARBONATE: BICARBONATE < 1.5 me/l IS SATISFACTORY FOR OVERHEAD SPRINKLERS.

SAR: SODIUM ADSORPTION RATIO. A RATIO OF SODIUM TO CALCIUM AND MAGNESIUM.

CHLORIDE: FOR SURFACE IRRIGATION CHLORIDE < 4 me/l IS GOOD.

EVALUATE WITH EC.
 SAR = 0 - 3 AND EC > 400 ACCEPTABLE
 SAR = 3 - 6 AND EC > 900 ACCEPTABLE

TDS: TDS < 450 IS ACCEPTABLE FOR UNRESTRICTED USE.

GYPSUM: AMOUNT OF CALCIUM SULFATE IN POUNDS PER ACRE-FOOT OF WATER APPLIED. INCREASES WATER PERMEABILITY AND HELPS CORRECT EXCESS SODIUM. INCREASES CLAY FLOCCULATION FOR INCREASING PERMEABILITY.

BORON: BORON < 0.50 mg/l IS SATISFACTORY FOR ALL CROPS. EXCESSIVE BORON IS PHYTOTOXIC (BURNS) TO PLANTS.