

EXHIBIT "C1"
ARVIN-EDISON WATER STORAGE DISTRICT
WATER SUPPLY WATER QUALITY SUMMARY

	Date	Flow	Import Source	Calcium		Magnesium		Sodium		Bicarbonate		Chloride		Nitrate		TDS	pH	EC	Hardness	SAR	Gypsum	Boron	Turbidity
		cfs		mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l		umhos/cm	mg/l		lbs/AF	mg/l	NTU
Intake Canal	08/05/25	226	FKC (55%)/CVC (45%)	13.0	0.7	7.7	0.6	26.0	1.1	58	1.0	31.0	0.9	ND	ND	160	7.6	240	64	6.4	0	ND	4.6
	07/09/25	251	FKC (60%)/CVC (40%)	20.0	1.0	12.0	1.0	45.0	1.9	64	1.0	57.0	1.6	ND	ND	240	8.6	410	99	4.0	N/A	110.00	4.5
	06/17/25	201	FKC (50%)/CVC (50%)	17.0	0.9	9.9	0.8	33.0	1.4	70	1.1	41.0	1.2	ND	ND	190	8.1	340	84	5.0	0.1	110.00	5.1
	05/01/25	100	FKC (100%)	10.0	0.5	5.0	0.4	18.0	0.8	45.0	0.7	22.0	0.6	ND	ND	120.0	7.9	190.0	46.0	7.0	0.1	ND	6.6
	04/10/25	300	FKC (100%)	4.3	0.2	0.8	0.1	4.2	0.2	20.0	0.3	2.8	0.1	ND	ND	53.0	6.9	51.0	14.0	4.0	0.1	ND	28.2
	03/04/25	0	WELLS(100%)	19.0	1.0	9.6	0.8	34.0	1.5	58.0	1.0	38.0	1.1	ND	ND	290.0	9.2	340.0	88.0	4.4	0.1	110.0	13.0
	02/11/25	70	CVC (100%)	21.0	1.1	12.0	1.0	46.0	2.0	75.0	1.2	55.0	1.5	1.4	0.02	220.0	8.5	420.0	100.0	3.6	0.2	170.0	6.0
	01/07/25	0	RESIDUAL/DEWATERED	21.0	1.1	10.0	0.8	50.0	2.2	110.0	1.8	57.0	1.6	3.4	0.05	220.0	8.3	430.0	97.0	2.7	0.2	160.0	14.4
	12/11/24	25	CVC (100%)	18.0	0.9	9.0	0.7	37.0	1.6	110.0	1.8	49.0	1.4	1.1	0.02	190.0	7.3	350.0	81.0	4.1	0.2	100.0	22.0
	11/08/24	0	DOWN FOR MAINTENANCE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	10/15/24	30	FKC(100%)	7.1	0.4	3.2	0.3	11.0	0.5	44.0	0.7	13.0	0.4	ND	ND	74.0	8.2	130	31.0	5.7	0.07	ND	2.9
	09/17/24	50	FKC (50%)/CVC (50%)	14.0	0.7	8.1	0.7	26.0	1.1	81.0	1.3	32.0	0.9	ND	ND	150.0	8.5	260	68.0	5.2	0.10	ND	3.3
	08/14/24	101	CVC (100%)	9.3	0.5	4.8	0.4	16.0	0.7	37.0	0.6	19.0	0.5	ND	ND	110.0	8.5	160	43.0	6.5	0.07	ND	7.2
	07/25/24	260	FKC (71%)/CVC (29%)	7.1	0.4	1.9	0.2	9.5	0.4	27	0.4	8.8	0.2	ND	ND	76	19.9	99	26	6.0	0.04	ND	2.6
	Average			13.9	0.7	7.2	0.6	27.4	1.2	61.5	1.0	32.7	0.9	2.0	0.0	161.0	9.0	263.1	64.7	5.0	0.1	126.7	9.3
North Canal	08/05/25	40	FKC (38%)/CVC (31%)/WELLS(31%)	24.0	1.2	6.1	0.5	47.0	2.0	95.0	1.6	28.0	0.8	6.5	0.1	230.0	7.2	360.0	85.0	4.6	0.3	330.0	3.3
	07/09/25	40	FKC (44%)/CVC (29%)/WELLS(27%)	24.0	1.2	7.9	0.6	52.0	2.2	87.0	1.4	39.0	1.1	6.9	0.1	240.0	8.4	410.0	92.0	4.1	N/A	340.0	5.1
	06/17/25	106	FKC (30%)/CVC (30%)/WELLS(40%)	33.0	1.7	9.8	0.8	48.0	2.1	100.0	1.6	37.0	1.0	11.0	0.2	290.0	8.3	470.0	120.0	0.7	0.2	330.0	4.9
	05/01/25	82	FKC (46%)/WELLS(54%)	29.0	1.5	8.4	0.7	52.0	2.2	97.0	1.6	41.0	1.2	7.8	0.1	270.0	8.4	460.0	110.0	1.9	0.3	390.0	6.3
	04/10/25	148	FKC (98%)/WELLS(2%)	6.4	0.3	1.0	0.1	5.8	0.3	26.0	0.4	3.4	0.1	ND	ND	32.0	7.2	71.0	20.0	4.4	0.1	ND	13.9
	03/04/25	28	WELLS(100%)	19.0	1.0	4.0	0.3	39.0	1.7	87.0	1.4	20.0	0.6	7.9	0.1	260.0	8.4	320.0	64.0	7.1	0.3	210.0	3.7
	02/11/25	8	CVC (100%)	44.0	2.2	10.0	0.8	73.0	3.1	120.0	2.0	43.0	1.2	27.0	0.4	360.0	8.3	620.0	150.0	ND	0.3	560.0	10.8
	01/07/25	58	WELLS(100%)	18.0	0.9	3.5	0.3	27.0	1.2	120.0	2.0	13.0	0.4	5.8	0.1	120.0	7.5	240.0	59.0	5.3	0.2	120.0	3.7
	12/11/24	0	DOWN FOR MAINTENANCE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	11/08/24	0	WELLS(100%)	22.0	1.1	4.3	0.4	29.0	1.3	96.0	1.6	12.0	0.3	8.4	0.1	180.0	7.5	300	74.0	48.0	0.2	ND	1.9
	10/15/24	48	FKC(23%)/WELLS(77%)	20.0	1.0	4.0	0.3	35.0	1.5	100.0	1.6	18.0	0.5	8.3	0.1	170.0	8.1	300	67.0	5.8	0.3	200.0	4.0
	09/17/24	38	FKC (17%)/CVC (17%)/WELLS(66%)	20.0	1.0	4.6	0.4	37.0	1.6	92.0	1.5	21.0	0.6	7.2	0.1	200.0	8.2	310	69.0	6.2	0.2	230.0	2.7
	08/14/24	164	CVC (47%)/WELLS(53%)	17.0	0.9	4.4	0.4	28.0	1.2	73.0	1.2	19.0	0.5	4.6	0.1	160.0	8.2	250	60.0	6.7	0.2	180.0	8.9
	07/25/24	243	FKC (50%)/CVC (20%)/WELLS(30%)	16.0	0.8	3.6	0.3	27.0	1.2	66.0	1.1	16.0	0.4	4.4	0.1	150.0	8.2	230	54.0	7.4	0.1	220.0	8.5
	Average			22.5	1.1	5.5	0.5	38.4	1.7	89.2	1.5	23.9	0.7	8.8	0.1	204.8	8.0	333.9	78.8	8.5	0.2	282.7	6.0
South Canal	08/05/25	24	FKC (37%)/CVC (30%)/WELLS(33%)	26.0	1.3	8.3	0.7	45.0	1.9	100.0	1.6	36.0	1.0	5.8	0.1	250.0	8.3	400.0	99.0	2.9	0.2	210.0	2.9
	07/09/25	134	FKC (42%)/CVC (29%)/WELLS(29%)	25.0	1.3	8.0	0.7	45.0	1.9	100.0	1.6	33.0	0.9	5.9	0.1	220.0	8.3	380.0	96.0	3.2	N/A	250.0	3.3
	06/17/25	274	FKC (27.7%)/CVC (27.7%)/WELLS(44.6%)	29.0	1.5	7.3	0.6	51.0	2.2	110.0	1.8	33.0	0.9	7.4	0.1	270.0	8.1	440.0	100.0	1.8	0.3	380.0	3.1
	05/01/25	70	FKC (42%)/WELLS(58%)	26.0	1.3	7.2	0.6	49.0	2.1	96.0	1.6	33.0	0.9	13.0	0.2	240.0	8.2	420.0	95.0	3.4	0.3	400.0	2.8
	04/10/25	130	FKC (98%)/WELLS(2%)	7.0	0.4	1.1	0.1	5.9	0.3	27.0	0.4	3.4	0.1	ND	ND	32.0	7.0	75.0	22.0	4.3	0.1	ND	15.9
	03/04/25	16	WELLS(100%)	20.0	1.0	5.0	0.4	44.0	1.9	88.0	1.4	25.0	0.7	6.4	0.1	180.0	8.7	350.0	71.0	6.1	0.3	290.0	7.5
	02/11/25	0	CVC (100%)	34.0	1.7	6.8	0.6	74.0	3.2	110.0	1.8	38.0	1.1	14.0	0.2	320.0	8.0	540.0	110.0	ND	0.4	630.0	6.1
	01/07/25	0	SPILLWAY(AQUEDUCT-100%)	16.0	0.8	3.8	0.3	27.0	1.2	110.0	1.8	13.0	0.4	4.1	0.1	140.0	8.0	240.0	56.0	6.2	0.2	140.0	9.5
	12/11/24	0	DOWN FOR MAINTENANCE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	11/08/24	0	WELLS(100%)	16.0	0.8	8.3	0.7	30.0	1.3	73.0	1.2	37.0	1.0	ND	ND	170.0	7.7	320	74.0	5.6	0.1	100.0	4.1
	10/15/24	0	FKC(23%)/WELLS(77%)	21.0	1.1	5.8	0.5	32.0	1.4	110.0	1.8	18.0	0.5	4.2	0.1	220.0	8.2	300	76.0	4.5	0.2	140.0	2.5
	09/17/24	20	FKC (16%)/CVC (16%)/WELLS(67%)	15.0	0.8	6.1	0.5	39.0	1.7	61.0	1.0	22.0	0.6	4.7	0.1	200.0	8.9	300	62.0	7.6	0.2	260.0	5.8
	08/14/24	152	CVC (38%)/WELLS(62%)	23.0	1.2	6.6	0.5	34.0	1.5	89.0	1.5	29.0	0.8	5.5	0.1	190.0	8.2	330	85.0	4.4	0.2	180.0	3.1
	07/25/24	182	FKC (45%)/CVC (18%)/WELLS(37%)	20.0	1.0	4.9	0.4	30.0	1.3	81.0	1.3	22.0	0.6	5.1	0.1	180.0	8.0	280	70.0	5.7	0.2	180.0	4.5
	Average			21.4	1.1	6.1	0.5	38.9	1.7	88.8	1.5	26.3	0.7	6.9	0.1	200.9	8.1	336.5	78.2	4.6	0.2	263.3	5.4

EXHIBIT "C1"
ARVIN-EDISON WATER STORAGE DISTRICT
WATER SUPPLY WATER QUALITY SUMMARY

	Date	Flow cfs	Import Source	Calcium		Magnesium		Sodium		Bicarbonate		Chloride		Nitrate		TDS	pH	EC	Hardness	SAR	Gypsum	Boron	Turbidity
				mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l	me/l	mg/l		umhos/cm	mg/l		lbs/AF	mg/l	NTU
Intertie Pipeline	08/05/25	123	FKC (31%)/CVC (25%)/WELLS(28%)/AQUEDUCT(16%)	13.0	0.7	7.6	0.6	25.0	1.1	60	1.0	31.0	0.9	ND	ND	160	7.5	250	63	6.3	0	ND	5.5
	07/09/25	63	FKC (36%)/CVC (24%)/WELLS(25%)/AQUEDUCT(15%)	20.0	1.0	11.0	0.9	43.0	1.9	70	1.1	56.0	1.6	1.0	0.0	230	8.1	400	N/A	4.2	N/A	130.00	8.0
	06/17/25	40	FKC (27.7%)/CVC (27.7%)/WELLS(44.6%)	25.0	1.3	8.5	0.7	49.0	2.1	88	1.4	36.0	1.0	5.0	0.1	250	8.6	410	97	3.1	0.2	360.00	4.0
	05/01/25	40	FKC (36%)/WELLS(49%)/SPILLWAY(14%)	22.0	1.1	5.4	0.4	42.0	1.8	83.0	1.4	25.0	0.7	5.7	0.1	220.0	8.6	350.0	77.0	5.2	0.3	370.0	6.3
	04/10/25	0	FKC (98%)/WELLS(2%)	8.7	0.4	1.2	0.1	6.3	0.3	31.0	0.5	3.6	0.1	ND	ND	61.0	7.3	84.0	27.0	4.0	0.1	ND	12.4
	03/04/25	0	WELLS(100%)	24.0	1.2	7.3	0.6	41.0	1.8	87.0	1.4	29.0	0.8	5.1	0.1	280.0	8.6	370.0	90.0	3.9	0.2	210.0	13.2
	02/11/25	0	CVC (100%)	19.0	1.0	6.2	0.5	45.0	1.9	74.0	1.2	35.0	1.0	3.3	0.1	200.0	8.8	340.0	73.0	6.5	0.2	270.0	13.5
	01/07/25	0	SPILLWAY(AQUEDUCT-100%)	19.0	1.0	12.0	1.0	55.0	2.4	93.0	1.5	83.0	2.3	2.0	0.0	230.0	7.8	480.0	97.0	3.1	0.2	120.0	6.0
	12/11/24	0	DOWN FOR MAINTENANCE	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	11/08/24	100	WELLS(51%)/AQUEDUCT(49%)	14.0	0.7	8.8	0.7	30.0	1.3	65.0	1.1	48.0	1.3	ND	ND	170.0	7.2	320	72.0	6.0	0.2	ND	5.4
	10/15/24	100	FKC(13%)/WELLS(44%)/AQUEDUCT(43%)	15.0	0.8	9.4	0.8	31.0	1.3	75.0	1.2	42.0	1.2	ND	ND	220.0	7.5	310	77.0	5.3	0.1	ND	4.4
	09/17/24	100	FKC (10%)/CVC (10%)/WELLS(40%)/AQUEDUCT(40%)	13.0	0.7	7.9	0.6	26.0	1.1	65.0	1.1	33.0	0.9	ND	ND	160.0	8.1	260	65.0	6.0	0.1	ND	6.5
	08/14/24	0	CVC (38%)/WELLS(62%)	23.0	1.2	6.5	0.5	35.0	1.5	81.0	1.3	28.0	0.8	4.9	0.1	200.0	8.5	330	83.0	4.5	0.2	220.0	3.8
	07/25/24	0	FKC (45%)/CVC (18%)/WELLS(37%)	22.0	1.1	5.8	0.5	31.0	1.3	69.0	1.1	24.0	0.7	5.8	0.1	190.0	20.1	300	78.0	5.1	0.2	200.0	3.4
	Average			18.3	0.9	7.5	0.6	35.3	1.5	72.4	1.2	36.4	1.0	4.1	0.1	197.8	9.0	323.4	74.9	4.9	0.2	235.0	7.1

Water Supply Water Quality Note: ¹ Positive flow rate is reverse flow into the District. Where the reported value is ND, the method detection limit is entered.

Water Supply Water Quality Note: ² Reverse flow into the District South Canal (Sycamore check gate was closed).

Water Supply Water Quality Note: ³ Constituent ran past sample hold time.

ND: NONE DETECTED.

N/A: NOT AVAILABLE OR NOT TESTED.

PR: PENDING RESULTS

mg/l: MILLIGRAMS PER LITER; SAME AS PARTS PER MILLION

me/l: MILLEQUIVALENTS PER LITER; SAME AS EQUIVALENTS

INTAKE: SAMPLE TAKEN AT COTTONWOOD RD. SOUTH OF PANAMA LANE.

NORTH: SAMPLE TAKEN DOWNSTREAM OF SYCAMORE CHECK GATE.

SOUTH: SAMPLE TAKEN DOWNSTREAM OF TEJON CHECK GATE.

INTERTIE: TERMINUS OF SOUTH CANAL (S93 FOREBAY).

SODIUM: FOR SURFACE IRRIGATION: SAR < 3 IS GOOD. FOR SPRINKLER IRRIGATION: SODIUM < 3 me/l IS GOOD.

NITRATE: NITRATE IN WATER SLIGHTLY REDUCES FERTILIZER REQUIREMENT.

BICARBONATE: BICARBONATE < 1.5 me/l IS SATISFACTORY FOR OVERHEAD SPRINKLERS.

CHLORIDE: FOR SURFACE IRRIGATION CHLORIDE < 4 me/l IS GOOD.

TDS: TDS < 450 IS ACCEPTABLE FOR UNRESTRICTED USE.

GYPSUM: AMOUNT OF CALCIUM SULFATE IN POUNDS PER ACRE-FOOT OF WATER APPLIED. INCREASES WATER PERMEABILITY AND HELPS CORRECT EXCESS SODIUM. INCREASES CLAY FLOCCULATION FOR INCREASING PERMEABILITY.

pH: A MEASURE OF ACIDITY. A pH < 7 IS ACIDIC, pH = 7 IS NEUTRAL, pH > 7 IS BASIC. NORMAL RANGE IS 6.5 - 8.4. A pH > 8 MAY NEED TO BE BUFFERED FOR PESTICIDE APPLICATION. AFFECTS NUTRIENT AVAILABILITY.

EC: ELECTRICAL CONDUCTIVITY. A MEASURE OF WATER SALINITY; SOIL - IN MILLIMHOS PER CENTIMETER (mmho/cm); WATER - MORE OFTEN, IN MICROMHOS PER CENTIMETER (umhos/cm). EC < 700 (umhos/cm) HAS NO RESTRICTIONS FOR AGRICULTURAL USE. EC < 200 (umhos/cm) CAN REDUCE INFILTRATION RATE.

HARDNESS: HARD WATER, INDICATING CALCIUM AND MAGNESIUM, IS BENEFICIAL FOR AGRICULTURE.

SAR: SODIUM ADSORPTION RATIO. A RATIO OF SODIUM TO CALCIUM AND MAGNESIUM. EVALUATE WITH EC. SAR = 0 - 3 AND EC > 400 ACCEPTABLE SAR = 3 - 6 AND EC > 900 ACCEPTABLE

BORON: BORON < 0.50 mg/l IS SATISFACTORY FOR ALL CROPS. EXCESSIVE BORON IS PHYTOTOXIC (BURNS) TO PLANTS.